



Material & Engineering Laboratory-Kaohsiung

Test Report



Report No. : KB-18-02441A

C-18-05331

Page No. : 1 OF 1

Date of Report : Mar. 30, 2018

Applicant

Supplier

Sample Name

Other Information

Sample Submitted By

Date of Sample Received

Date of Testing

Remark

HONG YUAN LIN TECHNOLOGY CO., LTD.

HONG YUAN LIN TECHNOLOGY CO., LTD.

VQ-900 Nano Silicate Concrete Densifier

Product type: VQ-900

HONG YUAN LIN TECHNOLOGY CO., LTD. (YEH, YAO-CHENG)

Mar. 16, 2018

Mar. 16, 2018~Apr. 30, 2018

1. The information mentioned in the above section is provided by Client
(Exclude Date of Sample Received and Date of Testing)

2. Sample delivered to the laboratory by courier.

Test Result :

Test Items	Test Method	Test Result	
		Control	Test
Water absorption(%)	ASTM C642-06	9.9	7.5
Non-absorbing rate increase ^{note1}		1.3	

Note. 1. Non-absorbing rate increase = control/test (customer supplied)

2. The Sample was made by the laboratory

3. Remark: This Test Report is an additional original report of KB-18-02441 C-18-05331.

Issued date : Mar. 30, 2018

----- oOo -----

Fonglin - Hsu

Signed for and on behalf of
SGS Taiwan Ltd.

The required specification(s) offered in this test report is/are for reference only.
The conformity judgment is at the Applicant's final verdict.

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Document.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.

SGS Taiwan Ltd.
台灣檢驗科技股份有限公司

No. 61, Kai-Fa Road, Nanzih Export Processing Zone, Kaohsiung, Taiwan / 高雄市楠梓加工出口區開發路61號
t (886-7) 301-2121 f (886-7) 301-1165
www.sgs.tw

Member of SGS Group

TWC4794937

2018