

Material and Engineering Laboratory-Taichung

TEST REPORT

A LANGKARA DA BARAN INA AN AN ANDREA DA BARAN BARAN

TV-18-01657A REPORT NO.

PAGE NO.

1 OF 1

DATE

Jun. 5, 2018

Applicant

HONG YUAN LIN TECHNOLOGY CO., LTD.

Product Description

WATER-BASED CONCRETE WATERPROOF SEALER

Product Type

VO-1009

Product Color

White Emulsion

Manufacturer

HONG YUAN LIN TECHNOLOGY CO., LTD.

Supplier

HONG YUAN LIN TECHNOLOGY CO., LTD.

Received Date

May 10, 2018

Tested Date

May 10, 2018~Jun. 5, 2018

Remark

The information mentioned in the above section is provided by Client

(Exclude Date of Sample Received and Date of Testing)

Test Result :

| Test Item | Unit | Test Method | Result | MDL |
|------------------------------------|--------|--------------------------------------|--------|-----|
| Formaldehyde (CAS No.:50-00-0) mg/ | ma/lra | With reference to ISO 17226-1(2008). | 8.56 | 3 |
| | mg/kg | Analysis was performed by HPLC/DAD. | | |

Note: 1. Formaldehyde test are subcontracted to SGS Central Chemical Laboratory-Taipei.

2. mg/kg = ppm; 0.1wt% = 1000 ppm; MDL = Method Detection Limit

3. This Test Report is an additional original report of TV-18-01657. Issued date: Jun. 5, 2018.

---- oOo ----

The required specification(s) offered in this test report is/are for reference only. The conformity judgment is at the Applicant's final verdict.

Signed for and on behalf of SGS TAIWAN Ltd.

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at http://www.sgs.com/en/Terms-and-Conditions.aspx and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at http://www.sgs.com/en/Terms-and-Conditions.aspx and for electronic format documents, subject to Terms and Conditions for Electronic Documents at <a href="http://www.sgs.com/en/Terms-and-Conditions/Terms-and-Cond

f (886-4) 2359-2557