

材料暨工程實驗室-台中

試驗報告



報告編號：TV-18-01659

頁數：1 OF 1

報告日期：107年08月01日

委託單位：泓垣霖科技有限公司
 產品名稱：水性混凝土防水密封劑
 產品型號：VQ-1009
 產品顏色：白色乳液
 製造廠商：泓垣霖科技有限公司
 供應廠商：泓垣霖科技有限公司
 收件日期：107年05月10日
 試驗日期：107年05月10日~107年08月01日
 備註：1.以上資料由顧客提供(收件及試驗日期除外)
 2.除非另有說明，此報告結果僅對測試之樣品負責
 未經本公司事先書面同意，此報告不可部分複製

x9



試驗結果：

試驗項目	試驗方法	試驗結果
耐酸性 (5%H ₂ SO ₄ ，室溫，168小時)	參考 ASTM D1308-02(2013)	無異狀
耐鹼性 (5%NaOH，室溫，168小時)	參考 ASTM D1308-02(2013)	無異狀

---oOo---

本傳真報告僅供參考

本報告若有提供規範值時，該規範值僅供參考，合格之判定以委託單位實際要求為準。


 報告簽署人


TEST REPORT



REPORT NO. TV-18-01659A
 PAGE NO. 1 OF 1
 DATE: Aug. 1, 2018

Applicant HONG YUAN LIN TECHNOLOGY CO., LTD.
 Product Description WATER-BASED CONCRETE WATERPROOF SEALER
 Product Type VQ-1009
 Product Color White Emulsion
 Manufacturer HONG YUAN LIN TECHNOLOGY CO., LTD.
 Supplier HONG YUAN LIN TECHNOLOGY CO., LTD.
 Received Date May 10, 2018
 Tested Date May 10, 2018~Aug. 1, 2018
 Remark The information mentioned in the above section is provided by Client
 (Exclude Date of Sample Received and Date of Testing)

Test Result :


Test Item	Test Method	Result
Resistance to chemicals (5% H ₂ SO ₄ , Room temp. , 168hr.)	Ref. ASTM D1308-02(2013)	No Effect
Resistance to chemicals (5% NaOH , Room temp. , 168hr.)	Ref. ASTM D1308-02(2013)	No Effect

Note : This Test Report is an additional original report of TV-18-01659. Issued date : Aug. 1, 2018.

---oOo---

本傳真報告僅供參考

The required specification(s) offered in this test report is/are for reference only.
 The conformity judgment is at the Applicant's final verdict.


 Signed for and on behalf of
 SGS Taiwan Ltd.

