



材料及工程實驗室-台中

試驗報告



報告編號: TV-14-02807X

頁數: 1 OF 1

報告日期: 103年 09月 22日


委託單位: 和友科技有限公司
 地址: 臺中市北屯區旱溪西路3段295巷31號
 產品名稱: 多功能防水乳膠樹脂
 產品型號: VQ-6000
 產品顏色: 白色乳液
 製造廠商: 和友科技有限公司
 送驗廠商: 和友科技有限公司
 收件日期: 103年 09月 09日
 試驗日期: 103年 09月 09日~103年 09月 22日
 備註: 1. 以上資料由顧客提供(收件及試驗日期除外)
 2. 除非另有說明, 此報告結果僅對測試之樣品負責
 未經本公司事先書面同意, 此報告不可部分複製

試驗結果

試驗項目	試驗方法	試驗結果
透水性(ml)(20±3°C, 24h)	CNS 10757(1995)	0.30

----- o o o -----

本報告若有提供規範值時, 該規範值僅供參考, 合格之判定以委託單位實際要求為準。


 報告簽署人

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Documents.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.